



# CITY OF RIVIERA BEACH

---

## PURCHASING DEPARTMENT

April 10, 2017

### Letter of Recommendation – Invitation to Bid 886-17-3. Removal of Two Underground Storage Tanks

**Background:** The Utility had a requirement for closure of one (1) underground storage tank, one with a capacity of 2,500 gallons and the removal of an above ground storage tank with a capacity of 8,000 gallons. Due to proximity of the 2,500 underground tank to an existing wall and storage pad, it is recommended by both proposers to leave the tank underground and provide closure in place vs. removal. The existing underground tank is double wall construction which permits this type of action.

Both the underground and above ground tank processes will be performed the supervision of a State of Florida Licensed Professional Geologist.

**Recommendation:** Purchasing conducted mandatory site visits with both contractors. Both contractors submitted responsive, responsible bids. The background check provided good references for the low, responsive, responsible bidder ATC Group Services, LLC. It is the recommendation by purchasing to proceed with ATC Group Services, LLC.

Should you have any questions, please do not hesitate to contact me.

Respectfully,

Dean Mealy, II  
City Purchasing Director