



MEMORANDUM

To: Mary F. Savage Dunham, AICP, CFM, Assistant Director of Development Service
From: John Armstrong, P.E., Senior Utility Engineer *John*
Date: May 10, 2021
Re: SP-21-03 - 1301 President Barack Obama Highway - Site Plan

Thank you for providing the above referenced the Site Plan Application. The Utility District does not approve the Site Plan Application with comments consistent with prior comments for SP-21-02. Please refer to the comments of April 23, 2021 for SP-21-02 - 1301 Barack Obama Highway Administrative Site Plan as follows:

1. The Utility District does not approve extending the length of the water main and existing backflow preventers further from the existing water main.
2. The Utility District does not approve the proposed installation of trees around the aforementioned water main.