

# Riviera Beach Utility Special District

## Water Distribution System East Area Unidirectional Flushing Plan

June 12, 2018




## 1. Introduction

Consent Order File No. WP-020-16 requires that the Riviera Beach Utility Special District (RBUD) develop a written flushing plan. The RBUD retained C Solutions Inc. and Hazen and Sawyer (Hazen) to prepare a unidirectional flushing (UDF) plan for the RBUD’s water distribution system. The following provides a brief overview of each section of this report:

- Section 1: Section 1 provides a brief overview of the RBUD’s water system along with a brief explanation of the purpose of UDF and how UDF can improve water quality through the control of nitrification.
- Section 2: Section 2 provides UDF planning goals and an explanation of how the UDF plan is broken down into areas, zones and flushing events.
- Section 3: Section 3 describes the UDF bidding documents that will be prepared to retain a UDF contractor to assist the RBUD and train its staff to perform UDF.
- Section 4: Section 4 describes certain challenges that the RBUD should expect during the performance of UDF and offers suggestions on overcoming these challenges
- Section 5: Section 5 concludes with recommendations for the RBUD staff going forward.
- Attachment A: Attachment A is the UDF plan.

### 1.1 Location Map

The RBUD owns and operates water supply, treatment, storage and distribution infrastructure. It supplies water to approximately 40,000 people within its service area. Riviera Beach is a coastal community located in Palm Beach County, Florida. The water treatment plant and utility administration facility are located at 600 West Blue Heron Boulevard, Riviera Beach, Florida 33404. Figure 1 illustrates a location map.



**Figure 1: Riviera Beach Utility District Location Map**

## 1.2 Distribution System Map

The RBUD’s water distribution system is comprised of about 186 miles of pipe ranging in size from 1 to 30-inches in diameter. Figure 2 presents a simplified illustration of the RBUD’s water distribution system.

## 1.3 What is Unidirectional Flushing?

The CRBUD utilize a chloramine disinfection strategy in its distribution system. Chloramine is used by most South Florida water suppliers to limit the formation of disinfection by-product (DBPs) in the distribution system. UDF is a common practice in South Florida for water systems that use chloramines. It is a routine maintenance to prevent water quality degradation resulting from nitrification. Nitrification is explained in more detail in the following subsection.

UDF is a systematic method of closing valves and opening hydrants to direct water through targeted segments of pipe. Flushing begins near sources such as water plants, trunk mains, and tanks. Closing certain valves in a prescribed sequence creates one-way flow into each segment from other pipes that have been flushed previously. Flowing hydrants – illustrated in Figure 3 – induce velocities high enough to scour sediment and biofilm from the walls of the pipes. Pipes 16-inch and larger cannot be included because flowing from hydrants cannot achieve sufficient scouring velocities.




**Figure 3: Hydrant Flushing**

## 1.4 What is Nitrification?

Nitrification is a microbial growth process that occur in water systems that contain chloramines. Nitrification consumes the chloramine disinfectant residual in the water piping. The key to stopping nitrification is to starve the nitrifying bacteria of nitrogen. The most effective way to do this is to temporarily convert the disinfectant from chloramine to free chlorine concurrent with the UDF to convey the free chlorine throughout the pipe network. It is recommended that this UDF plan be performed concurrent to temporarily converting the disinfectant from chloramine to free chlorine.

The Florida Department of Environmental Protection (FDEP) issued a memorandum dated May 10, 2018 that clarified Rule 62-555.822 for the Florida Administrative Code (FAC) that indicated that chlorine burns (i.e., the temporary switch from chloramine to free chlorine) should be kept to a maximum of 21 days.





**Figure 2: RBUD Water Distribution System**

## 2. UDF Plan Development

### 2.1 Introduction

This section briefly summarizes key UDF planning goals and report nomenclature.

### 2.2 Key UDF Planning Goals

The UDF Plan was developed using the WaterGEMS water distribution system hydraulic model prepared for the 2013 Water and Wastewater Master Plan. The goals of the UDF plan development were as follows:

- Minimum velocity = 3 fps (removes sediment)
- Desired velocity = 5 fps (promotes scouring)
- Minimum pressure = 20 psi
- Pipe flushing volume = 3 turnovers
- The UDF Plan is designed to start at the Water Treatment Plant (WTP) work outwards
- UDF must be implemented in a series of sequential steps as described in the flushing journals presented herein
- Pipes 16-inch diameter and larger are not flushable through traditional means of opening fire hydrants without an unacceptable reduction in system water pressure
- The UDF plan only routes water through pipes that were flushed in a prior sequence

### 2.3 Key Caution During UDF Implementation

While performing each flushing sequence, the flushing crew(s) should use flow measurement devices and flush at a rate equal to the “Predicted Flow” listed for the hydrant in the UDF plan. Flushing at a rate higher than the “Predicted Flow” may cause unacceptably low pressures within the water distribution system.

### 2.4 Opening Multiple Ports on a Hydrant

Most UDF can be performed by opening a single port on a fire hydrant. For some flushing sequences, opening a single port will not be sufficient to achieve scouring velocity. For these cases, both 2.5-inch ports can be opened to achieve the predicted flow. When both hydrant ports are open, the flow may be measured on one of the ports, then doubled to calculate the total hydrant flow.

## 2.5 Certain Pipes Cannot be Flushed

Certain pipes are not flushable, as follows:

- Pipes 16-inch diameter and larger
- Small dead-end pipes without hydrants
- Looped pipes that do not include isolation valves where pressures dropped below 20 psi before reaching cleaning velocity

Pipes that are not flushable are colored purple in the journal maps.

## 2.6 The UDF Plan is Divided into Three Areas

The UDF Plan is divided into three areas based upon geographic region within the distribution system. The three areas are as follows:

- East Area: The East Area includes all piping on the barrier island
- West Area: The West Area includes all piping west of Garden Road
- Central Area: The Central Area includes all piping between the East and West Areas.

Figure 4 illustrates the geographic breakdown of the UDF Plan volumes. Each of these areas can be flushed independent of each other.




Figure 4: UDF Plan Areas

## 2.7 Each Area is Divided into Zones

Each area is further divided into a series of zones. For example, the West Area is divided into 11 flushing zones as illustrated in Figure 5. When flushing an area, flushing should begin with Zone 1 and through each zone in numerical order.




Figure 5: Example of a Zone Map

## 2.8 Each Zone is Divided into Flushing Events

Each zone is divided into a series of flushing events. During an event, valves are closed, and hydrants opened to flush a certain segment of piping within the zone being flushed. Each event is illustrated in a flushing event map that illustrates the location of the valves and hydrants for the flushing crew to operate. Figure 6 presents an example flushing event map.



Study: West; Area: Zone 1; Event: 1  
 Primary View

Legend

-  Valves to Open
-  Valves to Close
-  Flushing Hydrants
-  Pipe Run
-  Closed Pipes



Figure 6: Example Flushing Event Map



## **2.9 Flushing Event Form**

### **2.9.1 Flush Plan Information on Event Form**

The UDF Plan includes a flushing event form that presents the following information:

- Pipes to be flushed
- Valve identification numbers to be opened or closed
- Hydrant identification numbers to be flushed
- Predicted flow rate during flushing
- Predicted pressures while flushing
- Recommended flushing duration
- Recommended flushing volume

### **2.9.2 Data to Collect During Flushing on Event Form**

For each flushing event, the flushing crew should record the following data on the flushing event form:

- Water quality observations
- Notes about the operability of the valves
- Measured flow during flushing in gallons per minute
- Notes regarding hydrant operability
- Measure total chlorine residual at the start of flushing
- Measure total chlorine residual at the end of flushing
- Flushing start and end time

Figure 7 illustrates an example of a flushing event form.

## Flushing Field Report

Study: West; Area: Zone 1; Event: 1

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
1-0071				45.9	1,084
1-0001				46.0	1,085

Valve	Operation	Notes	Flushing	Minimum	Recommended
V1-0185	Close <input type="checkbox"/>		Time (min)	2.0	6.1
V1-0235	Close <input type="checkbox"/>		Volume (gal)	4,383.7	13,151.0
	<input type="checkbox"/>		Start Time		
	<input type="checkbox"/>		End Time		
	<input type="checkbox"/>		Operator		
	<input type="checkbox"/>		Date		
	<input type="checkbox"/>		<b>Water Quality</b>	<b>Initial</b>	<b>Final</b>
	<input type="checkbox"/>		Clear	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>		Colored	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>		Chlorine Residual		
	<input type="checkbox"/>		Turbidity		
<b>Pipe Run to be Cleaned</b>					
P-3121, P-2543, P-2552, P-1420, P-0400					
Notes <u>2 hydrants flushing</u>					

Figure 7: Example Flushing Event Form

### 3. UDF Bidding Documents

The RBUD staff require assistance and training to perform its initial UDF. Hence, the first several UDFs should be performed by a contractor with expertise in implementing UDF so that the RBUD staff can gain experience in UDF implementation. Hazen will prepare bidding documents for the RBUD to advertise and receive bids by contractors with expertise in implementing UDF.

Contractors that typically perform this type of work are as follows:

**HydroMax USA**

Shane Majetich  
Water Solutions Director  
2500 Drane Field Rd, Suite 204  
Lakeland, FL 33811  
Phone: (813) 305-6610  
Fax: (502) 565-0239

**Wachs Water Services**

Brad Gresham  
Business Development Manager – South Region  
Mobile: 678-340-6850  
bgresham@wachsws.com

**Mueller Service Co.**

Andrew Apgar  
National Sales Manager  
2004 Wood Court, Ste C  
Plant City, FL 33563  
Phone: (813) 764-8183 x106  
aapgar@muellerservicecompany.com

### 4. Challenges and Recommendations

The UDF plan prepared herein assumed that the existing water distribution system valves and hydrants are operable. The RBUD staff recognize that not all valves in its system are operable. Hence, during the performance of the first UDF, the RBUD will find that certain flushing events will not be able to be performed because of one of the following:

- The valve indicated in the UDF plan to be operated could not be found in the field<sup>1</sup>.
- The valve shown in the UDF plan to be operated was found but was not operable.

---

<sup>1</sup> This might indicate that the valve box was paved over or that the valve was in the RBUD's geographic information system but doesn't exist in the field.




When this challenge occurs, the RBUD staff will need to have its consultant attempt to develop an alternative sequence or “work-around”. The current contract with C Solutions Inc. includes “as-needed” assistance to address this issue on a time and materials basis.

The following recommendations are offered to further address this challenge:

- Hazen will prepare the UDF bidding documents to include stand-by time for the UDF contractor. This will allow time for the City’s consultant to run the UDF model to develop an alternative flushing sequence if inoperable valves are found.
- Hazen will prepare the UDF bidding documents to require that the UDF contractor create a database of all valves and hydrants it operates and notes valves and hydrants with maintenance issues.
- It is recommended that the City retain a water distribution system maintenance contractor to implement and valve and hydrant exercise and maintenance plan.


**Attachment A**  
**Unidirectional Flushing Plan**

# Riviera Beach UDF Area Map





# Riviera Beach UDF East Area









**Riviera Beach UDF East Area Summary Table**

<b>Zone</b>	<b>No. of Closed Operations</b>	<b>No. of Open Operations</b>	<b>Total no. of valve operations</b>	<b>Total length of pipes flushed (ft)</b>	<b>Total recommended flushing time (min)</b>	<b>Total volume flushed (gal)</b>	<b>No. of Events</b>
Zone 1	11	11	22	26,021	272	209,053	8
Zone 2	14	14	28	18,948	170	121,989	11
Zone 3	20	20	40	22,717	175	243,321	8
Zone 4	19	19	38	19,705	168	160,595	6
Zone 5	14	14	28	21,619	161	178,747	9
<b>Total</b>	<b>78</b>	<b>78</b>	<b>156</b>	<b>109,010</b>	<b>946</b>	<b>913,705</b>	

# Flushing Field Report

Study: East

Legend	
	Valves to Open
	Valves to Close
	Flushing Hydrants
	Pipe Run
	Closed Pipes
	Dead End Pipes


## East Area - Zone 1



# Flushing Field Report

Study: East; Area: Zone 1; Event: 1

Primary View



Riviera Beach, FL

## Flushing Field Report

Study: East; Area: Zone 1; Event: 1

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0006				51.1	858


Valve	Operation	Notes	Flushing	Minimum	Recommended
	<input type="checkbox"/>		Time (min)	12.6	37.9
	<input type="checkbox"/>		Volume (gal)	10,832.9	32,498.6
	<input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-2474, P-8477, P-8476, P-8475, P-8474, P-1229, P-1228, P-2399(1), P-2399(2),			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-2391(1), P-2391(2), P-1173, P-1590, P-1589, P-2362, P-2360			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 1; Event: 2

Primary View



Riviera Beach, FL

## Flushing Field Report

Study: East; Area: Zone 1; Event: 2

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0001				41.3	900


Valve	Operation	Notes	Flushing	Minimum	Recommended
	<input type="checkbox"/>		Time (min)	14.6	43.9
	<input type="checkbox"/>		Volume (gal)	13,162.8	39,488.4
	<input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-2359, P-2357, P-2222, P-2221, P-2354, P-2352, P-2350			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 1; Event: 3

Primary View



## Flushing Field Report

Study: East; Area: Zone 1; Event: 3

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0017				23.7	682


Valve	Operation	Notes	Flushing	Minimum	Recommended
	<input type="checkbox"/>		Time (min)	4.7	14.0
	<input type="checkbox"/>		Volume (gal)	3,187.1	9,561.3
	<input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-8443, P-8442, P-2486, P-2484(1), P-2485, P-2481, P-2479			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_



# Flushing Field Report

Study: East; Area: Zone 1; Event: 4



## Flushing Field Report

Study: East; Area: Zone 1; Event: 4

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0022				20.6	567


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0607	Close <input type="checkbox"/>		Time (min)	10.3	30.9
V3-0312	Close <input type="checkbox"/>		Volume (gal)	5,849.6	17,548.7
V3-0376	Close <input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-2873, P-2876, P-2877, P-2874, P-2852, P-2846, P-2839, P-2532, P-2533, P-2838,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-2535, P-2534			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 1; Event: 5

Primary View



## Flushing Field Report

Study: East; Area: Zone 1; Event: 5

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0025				24.9	723


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0607	Closed (prior) <input type="checkbox"/>		Time (min)	15.9	47.6
V3-0312	Closed (prior) <input type="checkbox"/>		Volume (gal)	11,466.7	34,400.1
V3-0376	Closed (prior) <input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>		<b>Water Quality</b>		
	<input type="checkbox"/>			<b>Initial</b>	<b>Final</b>
	<input type="checkbox"/>		Clear	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>		Colored	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>		Chlorine Residual		
	<input type="checkbox"/>		Turbidity		
<b>Pipe Run to be Cleaned</b>					
P-2853, P-2851, P-2868, P-2869, P-2867, P-2870, P-2866, P-2864, P-2875, P-2879,					
P-1378					

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 1; Event: 6

Primary View



## Flushing Field Report

Study: East; Area: Zone 1; Event: 6

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0029				25.2	702

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0376	Reopen <input type="checkbox"/>		Time (min)	11.0	33.0
V3-0607	Closed (prior) <input type="checkbox"/>		Volume (gal)	7,727.1	23,181.3
V3-0312	Closed (prior) <input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-2880, P-3143, P-2538, P-2536, P-3147, P-3144, P-3145			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		


Notes \_\_\_\_\_



# Flushing Field Report

Study: East; Area: Zone 1; Event: 7

Primary View



## Flushing Field Report

Study: East; Area: Zone 1; Event: 7

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0042				30.7	776


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0312	Reopen <input type="checkbox"/>		Time (min)	9.2	27.6
V3-0607	Closed (prior) <input type="checkbox"/>		Volume (gal)	7,147.6	21,442.8
V3-0212	Close <input type="checkbox"/>		Start Time _____		
V3-0227	Close <input type="checkbox"/>		End Time _____		
V3-0583	Close <input type="checkbox"/>		Operator _____		
V3-0574	Close <input type="checkbox"/>		Date _____		
V3-0228	Close <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-3125(1), P-3125(2), P-3127, P-2546, P-3205, P-3572, P-2589, P-2910, P-4165			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 1; Event: 8

Primary View



## Flushing Field Report

Study: East; Area: Zone 1; Event: 8

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0042				36.2	843

Valve	Operation	Notes	Flushing	Minimum	Recommended															
V3-0583	Reopen <input type="checkbox"/>		Time (min)	12.2	36.7															
V3-0574	Reopen <input type="checkbox"/>		Volume (gal)	10,310.5	30,931.5															
V3-0607	Closed (prior) <input type="checkbox"/>		Start Time _____																	
V3-0227	Closed (prior) <input type="checkbox"/>		End Time _____																	
V3-0212	Closed (prior) <input type="checkbox"/>		Operator _____																	
V3-0228	Closed (prior) <input type="checkbox"/>		Date _____																	
V3-0582	Close <input type="checkbox"/>		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">Water Quality</th> <th style="width: 15%;">Initial</th> <th style="width: 25%;">Final</th> </tr> </thead> <tbody> <tr> <td>Clear</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>Colored</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>Chlorine Residual</td> <td></td> <td></td> </tr> <tr> <td>Turbidity</td> <td></td> <td></td> </tr> </tbody> </table>			Water Quality	Initial	Final	Clear	<input type="checkbox"/>	<input type="checkbox"/>	Colored	<input type="checkbox"/>	<input type="checkbox"/>	Chlorine Residual			Turbidity		
Water Quality	Initial	Final																		
Clear	<input type="checkbox"/>	<input type="checkbox"/>																		
Colored	<input type="checkbox"/>	<input type="checkbox"/>																		
Chlorine Residual																				
Turbidity																				
V3-0601	Close <input type="checkbox"/>																			
V3-0479	Close <input type="checkbox"/>																			
	<input type="checkbox"/>																			
	<input type="checkbox"/>																			
<b>Pipe Run to be Cleaned</b>																				
P-4196, P-4283, P-4286, P-4285, P-4280(2)(2), P-4280(2)(1), P-4280(1)(2),																				
P-4280(1)(1)(2), P-4280(1)(1)(1), P-8829(2), P-8829(1)(1), P-8829(1)(2), P-0167, P-8779, P-8780, P-8737(																				

Notes \_\_\_\_\_

## Flushing Field Report







Study: East; Area: Zone 1; Event: 8

### Final Actions

Valve	Operation	Notes
V3-0607	Reopen <input type="checkbox"/>	
V3-0227	Reopen <input type="checkbox"/>	
V3-0212	Reopen <input type="checkbox"/>	
V3-0228	Reopen <input type="checkbox"/>	
V3-0582	Reopen <input type="checkbox"/>	
V3-0601	Reopen <input type="checkbox"/>	
V3-0479	Reopen <input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	

# Flushing Field Report

Study: East

Legend	
	Valves to Open
	Valves to Close
	Flushing Hydrants
	Pipe Run
	Closed Pipes
	Dead End Pipes


## East Area - Zone 2



# Flushing Field Report

Study: East; Area: Zone 2; Event: 1

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 1

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0036				20.6	263


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0215	Close <input type="checkbox"/>		Time (min)	27.4	82.2
V3-0217	Close <input type="checkbox"/>		Volume (gal)	7,204.4	21,613.1
V3-0227	Close <input type="checkbox"/>		Start Time _____		
V3-0213	Close <input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-3206, P-3198, P-3186, P-3179, P-3223, P-3647, P-3651, P-1374, P-3650, P-3664,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-3680, P-2907, P-3724, P-3731, P-2889, P-2906, P-2908			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes	Recommended flushing time is 30 minutes
-------	---

# Flushing Field Report

Study: East; Area: Zone 2; Event: 2

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 2

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0036				44.4	933


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0227	Reopen <input type="checkbox"/>		Time (min)	2.0	5.9
V3-0213	Reopen <input type="checkbox"/>		Volume (gal)	1,832.1	5,496.4
V3-0215	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0217	Closed (prior) <input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-0789, P-2570			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 2; Event: 3

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 3

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0037				42.4	521

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0215	Reopen <input type="checkbox"/>		Time (min)	3.6	10.7
V3-0217	Reopen <input type="checkbox"/>		Volume (gal)	1,862.5	5,587.5
V3-0218	Close <input type="checkbox"/>		Start Time _____		
V3-0222	Close <input type="checkbox"/>		End Time _____		
V3-0212	Close <input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-2922, P-2923, P-2909, P-2911, P-2917			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		


Notes \_\_\_\_\_



# Flushing Field Report

Study: East; Area: Zone 2; Event: 4

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 4

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0038				22.8	382


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0212	Reopen <input type="checkbox"/>		Time (min)	11.6	34.9
V3-0219	Close <input type="checkbox"/>		Volume (gal)	4,450.1	13,350.2
V3-0222	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0218	Closed (prior) <input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-3753, P-3749, P-3742, P-3740, P-3737, P-3275, P-3747			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 2; Event: 5

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 5

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0038				31.7	788


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0219	Reopen <input type="checkbox"/>		Time (min)	0.7	2.0
V3-0222	Closed (prior) <input type="checkbox"/>		Volume (gal)	520.7	1,562.2
V3-0218	Closed (prior) <input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-3748				<b>Initial</b>	<b>Final</b>
			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 2; Event: 6

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 6

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0044				40.9	896


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0222	Closed (prior) <input type="checkbox"/>		Time (min)	6.7	20.2
V3-0218	Closed (prior) <input type="checkbox"/>		Volume (gal)	6,031.5	18,094.4
V3-0235	Close <input type="checkbox"/>		Start Time _____		
V3-0231	Close <input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-4263, P-4262, P-4242, P-4221			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 2; Event: 7

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 7

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0044				48.9	979

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0222	Reopen <input type="checkbox"/>		Time (min)	6.3	18.9
V3-0231	Closed (prior) <input type="checkbox"/>		Volume (gal)	6,178.3	18,534.8
V3-0235	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0218	Closed (prior) <input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-3923, P-2633			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		


Notes \_\_\_\_\_



# Flushing Field Report

Study: East; Area: Zone 2; Event: 8

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 8

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0041				45.0	805


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0218	Closed (prior) <input type="checkbox"/>		Time (min)	0.9	2.7
V3-0231	Closed (prior) <input type="checkbox"/>		Volume (gal)	734.9	2,204.6
V3-0235	Closed (prior) <input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>		<b>Water Quality</b>		
	<input type="checkbox"/>			<b>Initial</b>	<b>Final</b>
	<input type="checkbox"/>		Clear	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>		Colored	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>		Chlorine Residual		
	<input type="checkbox"/>		Turbidity		
<b>Pipe Run to be Cleaned</b>					
P-4261, P-4255, P-4226					

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 2; Event: 9

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 9

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0041				51.4	1,003

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0218	Reopen <input type="checkbox"/>		Time (min)	1.0	3.1
V3-0235	Closed (prior) <input type="checkbox"/>		Volume (gal)	1,036.8	3,110.3
V3-0231	Closed (prior) <input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-3893				<b>Initial</b>	<b>Final</b>
			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 2; Event: 10

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 10

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0046				32.1	793


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0235	Closed (prior) <input type="checkbox"/>		Time (min)	9.2	27.6
V3-0231	Closed (prior) <input type="checkbox"/>		Volume (gal)	7,309.7	21,929.2
V3-0234	Close <input type="checkbox"/>		Start Time _____		
V3-0400	Close <input type="checkbox"/>		End Time _____		
V3-0241	Close <input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-2820, P-4287, P-4276, P-1688, P-1690, P-4392, P-4600, P-4609, P-4730, P-4358,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-4387			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 2; Event: 11

Primary View



## Flushing Field Report

Study: East; Area: Zone 2; Event: 11

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0046				42.7	784

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0235	Reopen <input type="checkbox"/>		Time (min)	4.5	13.4
V3-0231	Reopen <input type="checkbox"/>		Volume (gal)	3,502.2	10,506.6
V3-0234	Reopen <input type="checkbox"/>		Start Time _____		
V3-0241	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0226	Close <input type="checkbox"/>		Operator _____		
V3-0400	Closed (prior) <input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-4274, P-4267, P-4340, P-4610, P-4730			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_



## Flushing Field Report







Study: East; Area: Zone 2; Event: 11

### Final Actions

Valve	Operation	Notes
V3-0241	Reopen <input type="checkbox"/>	
V3-0226	Reopen <input type="checkbox"/>	
V3-0400	Reopen <input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	

# Flushing Field Report

Study: East


Legend	
	Valves to Open
	Valves to Close
	Flushing Hydrants
	Pipe Run
	Closed Pipes
	Dead End Pipes

## East Area - Zone 3

# Flushing Field Report

Study: East; Area: Zone 3; Event: 1

Primary View



Riviera Beach, FL

## Flushing Field Report

Study: East; Area: Zone 3; Event: 1

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0050				23.4	677
3-0054				31.6	787


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0478	Close <input type="checkbox"/>		Time (min)	6.9	20.7
V3-0248	Close <input type="checkbox"/>		Volume (gal)	10,108.5	30,325.6
V3-0582	Close <input type="checkbox"/>		Start Time _____		
V3-0316	Close <input type="checkbox"/>		End Time _____		
V3-0182	Close <input type="checkbox"/>		Operator _____		
V3-0181	Close <input type="checkbox"/>		Date _____		
V3-0243	Close <input type="checkbox"/>				
V3-0238	Close <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-4641, P-4720, P-4718(2)(2)(2), P-4718(2)(2)(1), P-4943(1)(1), P-4718(1),				<b>Initial</b>	<b>Final</b>
P-4718(2)(1), P-4943(1)(2), P-4943(2), P-1190(2), P-1190(1), P-5037, P-1189, P-8941, P-8942, P-8943, P-			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes	<u>2 hydrants flushing</u>
-------	----------------------------

# Flushing Field Report

Study: East; Area: Zone 3; Event: 2

Primary View



Riviera Beach, FL

## Flushing Field Report

Study: East; Area: Zone 3; Event: 2

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0049				55.7	1,045

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0248	Reopen <input type="checkbox"/>		Time (min)	5.5	16.6
V3-0582	Reopen <input type="checkbox"/>		Volume (gal)	5,778.4	17,335.1
V3-0182	Reopen <input type="checkbox"/>		Start Time _____		
V3-0316	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0243	Closed (prior) <input type="checkbox"/>		Operator _____		
V3-0238	Closed (prior) <input type="checkbox"/>		Date _____		
V3-0181	Closed (prior) <input type="checkbox"/>				
V3-0478	Closed (prior) <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-4628, P-4723, P-4722, P-4788, P-4809, P-4817, P-4825				<b>Initial</b>	<b>Final</b>
			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes _____
-------------

# Flushing Field Report

Study: East; Area: Zone 3; Event: 3

Primary View



## Flushing Field Report

Study: East; Area: Zone 3; Event: 3

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0056				21.1	505

Valve	Operation	Notes	Flushing	Minimum	Recommended															
V3-0316	Reopen <input type="checkbox"/>		Time (min)	9.7	29.2															
V3-0238	Reopen <input type="checkbox"/>		Volume (gal)	4,912.6	14,737.9															
V3-0255	Close <input type="checkbox"/>		Start Time _____																	
V3-0191	Close <input type="checkbox"/>		End Time _____																	
V3-0252	Close <input type="checkbox"/>		Operator _____																	
V3-0404	Close <input type="checkbox"/>		Date _____																	
V3-0243	Closed (prior) <input type="checkbox"/>		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">Water Quality</th> <th style="width: 20%;">Initial</th> <th style="width: 20%;">Final</th> </tr> </thead> <tbody> <tr> <td>Clear</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>Colored</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>Chlorine Residual</td> <td></td> <td></td> </tr> <tr> <td>Turbidity</td> <td></td> <td></td> </tr> </tbody> </table>			Water Quality	Initial	Final	Clear	<input type="checkbox"/>	<input type="checkbox"/>	Colored	<input type="checkbox"/>	<input type="checkbox"/>	Chlorine Residual			Turbidity		
Water Quality	Initial	Final																		
Clear	<input type="checkbox"/>	<input type="checkbox"/>																		
Colored	<input type="checkbox"/>	<input type="checkbox"/>																		
Chlorine Residual																				
Turbidity																				
V3-0181	Closed (prior) <input type="checkbox"/>																			
V3-0478	Closed (prior) <input type="checkbox"/>																			
	<input type="checkbox"/>																			
	<input type="checkbox"/>																			
<b>Pipe Run to be Cleaned</b>																				
P-5003, P-5004, P-1700(2), P-3365, P-3364, P-3363, P-3361, P-3360, P-3359, P-5252,																				
P-5261, P-1700(1)																				

Notes \_\_\_\_\_



# Flushing Field Report

Study: East; Area: Zone 3; Event: 4

Primary View



Riviera Beach, FL

## Flushing Field Report

Study: East; Area: Zone 3; Event: 4

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0055				55.2	1,115


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0252	Reopen <input type="checkbox"/>		Time (min)	11.1	33.4
V3-0243	Reopen <input type="checkbox"/>		Volume (gal)	12,422.7	37,268.2
V3-0181	Reopen <input type="checkbox"/>		Start Time _____		
V3-0255	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0191	Closed (prior) <input type="checkbox"/>		Operator _____		
V3-0404	Closed (prior) <input type="checkbox"/>		Date _____		
V3-0478	Closed (prior) <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-4824, P-4998, P-5248, P-3362, P-3962, P-4996			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 3; Event: 5

Primary View



## Flushing Field Report

Study: East; Area: Zone 3; Event: 5

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0057				33.1	834


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0255	Reopen <input type="checkbox"/>		Time (min)	7.1	21.4
V3-0191	Reopen <input type="checkbox"/>		Volume (gal)	5,960.5	17,881.6
V3-0404	Reopen <input type="checkbox"/>		Start Time _____		
V3-0192	Close <input type="checkbox"/>		End Time _____		
V3-0201	Close <input type="checkbox"/>		Operator _____		
V3-0198	Close <input type="checkbox"/>		Date _____		
V3-0485	Close <input type="checkbox"/>				
V3-0189	Close <input type="checkbox"/>				
V3-0200	Close <input type="checkbox"/>				
V3-0478	Closed (prior) <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-3355, P-3379, P-5452, P-5120, P-0272, P-5251, P-5255, P-5257, P-5260, P-5262,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-5266, P-5267, P-5258, P-5420, P-4907			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 3; Event: 6

Primary View



## Flushing Field Report

Study: East; Area: Zone 3; Event: 6

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0062				60.4	1,088


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0189	Reopen <input type="checkbox"/>		Time (min)	0.5	1.6
V3-0478	Reopen <input type="checkbox"/>		Volume (gal)	592.8	1,778.3
V3-0201	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0485	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0200	Closed (prior) <input type="checkbox"/>		Operator _____		
V3-0198	Closed (prior) <input type="checkbox"/>		Date _____		
V3-0192	Closed (prior) <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-5296, P-5278			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 3; Event: 7

Primary View



## Flushing Field Report

Study: East; Area: Zone 3; Event: 7

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0068				32.5	798
3-0067				50.1	991

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0200	Closed (prior) <input type="checkbox"/>		Time (min)	20.3	60.8
V3-0198	Closed (prior) <input type="checkbox"/>		Volume (gal)	36,230.5	108,691.4
V3-0201	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0485	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0195	Close <input type="checkbox"/>		Operator _____		
V3-0192	Closed (prior) <input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-4466, P-4461, P-4442, P-4450, P-1345, P-1343(1), P-5720, P-1344, P-8384, P-1346,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-5874(2), P-5941, P-5943, P-5873, P-5724, P-2183, P-6096, P-6133, P-3455, P-6097, P-5728			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		


Notes 2 hydrants flushing; Recommended flushing time is 30 minutes



# Flushing Field Report

Study: East; Area: Zone 3; Event: 8

Primary View



## Flushing Field Report

Study: East; Area: Zone 3; Event: 8

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0068				28.4	693

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0200	Reopen <input type="checkbox"/>		Time (min)	7.4	22.1
V3-0195	Reopen <input type="checkbox"/>		Volume (gal)	5,100.9	15,302.7
V3-0198	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0201	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0485	Closed (prior) <input type="checkbox"/>		Operator _____		
V3-0194	Close <input type="checkbox"/>		Date _____		
V3-0192	Closed (prior) <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-5711, P-4035, P-3388, P-5936, P-4077, P-4078, P-5404, P-5295, P-5263, P-5244,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-5425, P-1161, P-5421, P-1162, P-3371, P-8923, P-0150, P-7076(1), P-7076(2), P-2857(1), P-2857(2)			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

## Flushing Field Report







Study: East; Area: Zone 3; Event: 8

### Final Actions

Valve	Operation	Notes
V3-0198	Reopen <input type="checkbox"/>	
V3-0201	Reopen <input type="checkbox"/>	
V3-0485	Reopen <input type="checkbox"/>	
V3-0194	Reopen <input type="checkbox"/>	
V3-0192	Reopen <input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	

# Flushing Field Report

Study: East


Legend	
	Valves to Open
	Valves to Close
	Flushing Hydrants
	Pipe Run
	Closed Pipes
	Dead End Pipes

## East Area - Zone 4

# Flushing Field Report

Study: East; Area: Zone 4; Event: 1

Primary View



## Flushing Field Report

Study: East; Area: Zone 4; Event: 1

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0067				26.8	518


Valve	Operation	Valve	Operation	Flushing	Minimum	Recommended
V3-0199	Close <input type="checkbox"/>	V3-0274	Close <input type="checkbox"/>	Time (min)	9.1	27.3
V3-0195	Close <input type="checkbox"/>	V3-0208	Close <input type="checkbox"/>	Volume (gal)	4,702.9	14,108.7
V3-0201	Close <input type="checkbox"/>	V3-0485	Close <input type="checkbox"/>	Start Time		
V3-0263	Close <input type="checkbox"/>			End Time		
V3-0287	Close <input type="checkbox"/>			Operator		
V3-0286	Close <input type="checkbox"/>			Date		
V3-0207	Close <input type="checkbox"/>			<b>Water Quality</b>		
V3-0282	Close <input type="checkbox"/>				<b>Initial</b>	<b>Final</b>
V3-0196	Close <input type="checkbox"/>			Clear	<input type="checkbox"/>	<input type="checkbox"/>
V3-0280	Close <input type="checkbox"/>			Colored	<input type="checkbox"/>	<input type="checkbox"/>
V3-0284	Close <input type="checkbox"/>			Chlorine Residual		
V3-0283	Close <input type="checkbox"/>			Turbidity		
V3-0275	Close <input type="checkbox"/>					
<b>Pipe Run to be Cleaned</b>						
P-0794, P-5946, P-2968, P-6091, P-6270, P-6099, P-5771, P-6358, P-5994, P-5999,						
P-6006, P-6017, P-6022, P-6019, P-1555, P-1554, P-6361, P-5875, P-4504, P-6318, P-6279, P-6098						

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 4; Event: 2

Primary View



## Flushing Field Report

Study: East; Area: Zone 4; Event: 2

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0067				45.4	944

Valve	Operation	Valve	Operation	Flushing	Minimum	Recommended																					
V3-0199	Reopen <input type="checkbox"/>	V3-0274	Closed (prior) <input type="checkbox"/>	Time (min)	4.9	14.6																					
V3-0287	Reopen <input type="checkbox"/>	V3-0208	Closed (prior) <input type="checkbox"/>	Volume (gal)	4,580.2	13,740.7																					
V3-0195	Closed (prior) <input type="checkbox"/>	V3-0485	Closed (prior) <input type="checkbox"/>	Start Time _____																							
V3-0201	Closed (prior) <input type="checkbox"/>	V3-0395	Close <input type="checkbox"/>	End Time _____																							
V3-0263	Closed (prior) <input type="checkbox"/>			Operator _____																							
V3-0286	Closed (prior) <input type="checkbox"/>			Date _____																							
V3-0207	Closed (prior) <input type="checkbox"/>			<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">Water Quality</th> <th style="width: 10%;">Initial</th> <th style="width: 10%;">Final</th> </tr> </thead> <tbody> <tr> <td>Clear</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>Colored</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>Chlorine Residual</td> <td></td> <td></td> </tr> <tr> <td>Turbidity</td> <td></td> <td></td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>			Water Quality	Initial	Final	Clear	<input type="checkbox"/>	<input type="checkbox"/>	Colored	<input type="checkbox"/>	<input type="checkbox"/>	Chlorine Residual			Turbidity								
Water Quality	Initial	Final																									
Clear	<input type="checkbox"/>	<input type="checkbox"/>																									
Colored	<input type="checkbox"/>	<input type="checkbox"/>																									
Chlorine Residual																											
Turbidity																											
V3-0282	Closed (prior) <input type="checkbox"/>																										
V3-0196	Closed (prior) <input type="checkbox"/>																										
V3-0280	Closed (prior) <input type="checkbox"/>																										
V3-0284	Closed (prior) <input type="checkbox"/>																										
V3-0283	Closed (prior) <input type="checkbox"/>																										
V3-0275	Closed (prior) <input type="checkbox"/>																										
<b>Pipe Run to be Cleaned</b>																											
P-8109, P-8110, P-6273, P-6102, P-6356, P-6285, P-6008, P-6364, P-0970, P-5805																											


Notes \_\_\_\_\_



# Flushing Field Report

Study: East; Area: Zone 4; Event: 3

Primary View



## Flushing Field Report

Study: East; Area: Zone 4; Event: 3

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0081				46.7	1,150


Valve	Operation	Valve	Operation	Flushing	Minimum	Recommended
V3-0286	Reopen <input type="checkbox"/>	V3-0274	Closed (prior) <input type="checkbox"/>	Time (min)	10.0	29.9
V3-0207	Reopen <input type="checkbox"/>	V3-0275	Closed (prior) <input type="checkbox"/>	Volume (gal)	11,461.2	34,383.5
V3-0284	Reopen <input type="checkbox"/>			Start Time		
V3-0208	Reopen <input type="checkbox"/>			End Time		
V3-0395	Reopen <input type="checkbox"/>			Operator		
V3-0195	Closed (prior) <input type="checkbox"/>			Date		
V3-0201	Closed (prior) <input type="checkbox"/>			<b>Water Quality</b>	<b>Initial</b>	<b>Final</b>
V3-0263	Closed (prior) <input type="checkbox"/>			Clear	<input type="checkbox"/>	<input type="checkbox"/>
V3-0196	Closed (prior) <input type="checkbox"/>			Colored	<input type="checkbox"/>	<input type="checkbox"/>
V3-0485	Closed (prior) <input type="checkbox"/>			Chlorine Residual		
V3-0282	Closed (prior) <input type="checkbox"/>			Turbidity		
V3-0283	Closed (prior) <input type="checkbox"/>					
V3-0280	Closed (prior) <input type="checkbox"/>					
<b>Pipe Run to be Cleaned</b>						
P-6282, P-6363, P-3495(1), P-3471, P-3472, P-6014, P-6007, P-5983, P-6342, P-6011						

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 4; Event: 4

Primary View



## Flushing Field Report

Study: East; Area: Zone 4; Event: 4

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0082				49.6	1,200


Valve	Operation	Notes	Flushing	Minimum	Recommended																					
V3-0195	Reopen <input type="checkbox"/>		Time (min)	12.8	38.4																					
V3-0201	Reopen <input type="checkbox"/>		Volume (gal)	15,351.8	46,055.3																					
V3-0263	Reopen <input type="checkbox"/>		Start Time _____																							
V3-0196	Reopen <input type="checkbox"/>		End Time _____																							
V3-0485	Reopen <input type="checkbox"/>		Operator _____																							
V3-0282	Reopen <input type="checkbox"/>		Date _____																							
V3-0283	Reopen <input type="checkbox"/>		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">Water Quality</th> <th style="width: 20%;">Initial</th> <th style="width: 20%;">Final</th> </tr> </thead> <tbody> <tr> <td>Clear</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>Colored</td> <td style="text-align: center;"><input type="checkbox"/></td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>Chlorine Residual</td> <td></td> <td></td> </tr> <tr> <td>Turbidity</td> <td></td> <td></td> </tr> <tr> <td> </td> <td></td> <td></td> </tr> <tr> <td> </td> <td></td> <td></td> </tr> </tbody> </table>			Water Quality	Initial	Final	Clear	<input type="checkbox"/>	<input type="checkbox"/>	Colored	<input type="checkbox"/>	<input type="checkbox"/>	Chlorine Residual			Turbidity								
Water Quality	Initial	Final																								
Clear	<input type="checkbox"/>	<input type="checkbox"/>																								
Colored	<input type="checkbox"/>	<input type="checkbox"/>																								
Chlorine Residual																										
Turbidity																										
V3-0280	Reopen <input type="checkbox"/>																									
V3-0274	Reopen <input type="checkbox"/>																									
V3-0275	Reopen <input type="checkbox"/>																									
	<input type="checkbox"/>																									
	<input type="checkbox"/>																									
	<input type="checkbox"/>																									
<b>Pipe Run to be Cleaned</b>																										
P-3534, P-3473, P-6052, P-6379, P-6406, P-6525, P-2188, P-2202, P-6681, P-6783,																										
P-3540, P-6255, P-6539																										

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 4; Event: 5

Primary View



## Flushing Field Report

Study: East; Area: Zone 4; Event: 5

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0085				52.5	1,015


Valve	Operation	Notes	Flushing	Minimum	Recommended
	<input type="checkbox"/>		Time (min)	11.2	33.5
	<input type="checkbox"/>		Volume (gal)	11,332.8	33,998.3
	<input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>		<b>Water Quality</b>	<b>Initial</b>	<b>Final</b>
	<input type="checkbox"/>		Clear	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>		Colored	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>		Chlorine Residual		
	<input type="checkbox"/>		Turbidity		
<b>Pipe Run to be Cleaned</b>					
P-6431, P-6446, P-6538, P-6581, P-2191, P-6599, P-6685, P-6737, P-6784, P-6828,					
P-6827, P-6807, P-6808, P-6813, P-8129					

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 4; Event: 6

Primary View



## Flushing Field Report

Study: East; Area: Zone 4; Event: 6

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0085				28.8	751

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0357	Close <input type="checkbox"/>		Time (min)	8.1	24.4
V3-0327	Close <input type="checkbox"/>		Volume (gal)	6,102.9	18,308.8
	<input type="checkbox"/>		Start Time _____		
	<input type="checkbox"/>		End Time _____		
	<input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-2192, P-6686, P-6785, P-6830, P-6795				<b>Initial</b>	<b>Final</b>
			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_



## Flushing Field Report







Study: East; Area: Zone 4; Event: 6

### Final Actions

Valve	Operation	Notes
V3-0357	Reopen <input type="checkbox"/>	
V3-0327	Reopen <input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	

# Flushing Field Report

Study: East


Legend	
	Valves to Open
	Valves to Close
	Flushing Hydrants
	Pipe Run
	Closed Pipes
	Dead End Pipes

## East Area - Zone 5

# Flushing Field Report

Study: East; Area: Zone 5; Event: 1

Primary View



## Flushing Field Report

Study: East; Area: Zone 5; Event: 1

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0059				29.2	232

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0262	Close <input type="checkbox"/>		Time (min)	4.2	12.6
V3-0199	Close <input type="checkbox"/>		Volume (gal)	975.6	2,926.7
V3-0195	Close <input type="checkbox"/>		Start Time _____		
V3-0491	Close <input type="checkbox"/>		End Time _____		
V3-0485	Close <input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-5270, P-5287, P-2639, P-5288, P-5767, P-5853, P-5872, P-5768, P-3400, P-4493,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-5926, P-5876, P-5925			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 5; Event: 2

Primary View



## Flushing Field Report

Study: East; Area: Zone 5; Event: 2

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0059				56.2	375

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0485	Reopen <input type="checkbox"/>		Time (min)	8.1	24.4
V3-0262	Closed (prior) <input type="checkbox"/>		Volume (gal)	3,042.8	9,128.5
V3-0199	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0195	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0201	Close <input type="checkbox"/>		Operator _____		
V3-0491	Closed (prior) <input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-0121, P-8980, P-8981, P-3383, P-8983, P-3431, P-8993, P-8998, P-9001, P-9006,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-9018, P-9014, P-9011, P-9007, P-9008, P-9005, P-9004, P-5829, P-5830, P-9023, P-9024, P-9025, P-0109			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 5; Event: 3

Primary View



## Flushing Field Report

Study: East; Area: Zone 5; Event: 3

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0059				44.1	929

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0491	Reopen <input type="checkbox"/>		Time (min)	2.1	6.3
V3-0201	Closed (prior) <input type="checkbox"/>		Volume (gal)	1,942.8	5,828.5
V3-0199	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0262	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0195	Closed (prior) <input type="checkbox"/>		Operator _____		
V3-0276	Close <input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-8995, P-8994, P-8996, P-8997			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		


Notes \_\_\_\_\_



# Flushing Field Report

Study: East; Area: Zone 5; Event: 4

Primary View



## Flushing Field Report

Study: East; Area: Zone 5; Event: 4


Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-198				55.6	746

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0276	Reopen <input type="checkbox"/>		Time (min)	0.7	2.1
V3-0201	Closed (prior) <input type="checkbox"/>		Volume (gal)	532.9	1,598.6
V3-0199	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0262	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0195	Closed (prior) <input type="checkbox"/>		Operator _____		
	<input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-9000, P-8999, P-0186			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 5; Event: 5



## Flushing Field Report

Study: East; Area: Zone 5; Event: 5


Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0177				37.0	882

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0199	Closed (prior) <input type="checkbox"/>		Time (min)	34.0	102.1
V3-0262	Closed (prior) <input type="checkbox"/>		Volume (gal)	30,003.4	90,010.3
V3-0195	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0201	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0169	Close <input type="checkbox"/>		Operator _____		
V3-0165	Close <input type="checkbox"/>		Date _____		
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-8126, P-6028, P-6225, P-6226, P-6029, P-6332, P-5382, P-3446, P-5959, P-4505,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-6274, P-6095, P-8111, P-2155, P-8112, P-8113, P-2163, P-5940, P-1160, P-1634, P-1635, P-1648, P-1649			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes    Recommended flushing time is 30 minutes

# Flushing Field Report

Study: East; Area: Zone 5; Event: 6



## Flushing Field Report

Study: East; Area: Zone 5; Event: 6


Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0177				38.6	870

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0165	Reopen <input type="checkbox"/>		Time (min)	4.2	12.5
V3-0199	Closed (prior) <input type="checkbox"/>		Volume (gal)	3,638.2	10,914.6
V3-0262	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0195	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0201	Closed (prior) <input type="checkbox"/>		Operator _____		
V3-0169	Closed (prior) <input type="checkbox"/>		Date _____		
V3-0174	Close <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-8114, P-8117, P-8118, P-8119, P-8120, P-8122(2), P-8122(1), P-8121, P-2147, P-8123, P-8125			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 5; Event: 7



## Flushing Field Report

Study: East; Area: Zone 5; Event: 7

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0070				41.4	901


Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0174	Reopen <input type="checkbox"/>		Time (min)	7.2	21.6
V3-0195	Closed (prior) <input type="checkbox"/>		Volume (gal)	6,475.5	19,426.4
V3-0199	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0262	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0201	Closed (prior) <input type="checkbox"/>		Operator _____		
V3-0323	Close <input type="checkbox"/>		Date _____		
V3-0169	Closed (prior) <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-2162, P-2159, P-3445, P-3440, P-6331, P-6328			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_



# Flushing Field Report

Study: East; Area: Zone 5; Event: 8



## Flushing Field Report

Study: East; Area: Zone 5; Event: 8


Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0074				41.0	897

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0323	Reopen <input type="checkbox"/>		Time (min)	6.5	19.6
V3-0169	Reopen <input type="checkbox"/>		Volume (gal)	5,852.2	17,556.6
V3-0195	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0262	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0199	Closed (prior) <input type="checkbox"/>		Operator _____		
V3-0201	Closed (prior) <input type="checkbox"/>		Date _____		
V3-0151	Close <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-8124, P-2144, P-2143, P-2142, P-2140, P-2139, P-2138, P-2137, P-2134, P-2132,				<b>Initial</b>	<b>Final</b>
P-2131, P-2128, P-2125, P-2127, P-2124, P-2123, P-2121, P-3093, P-3092, P-3091, P-3088			Clear	<input type="checkbox"/>	<input type="checkbox"/>
			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

# Flushing Field Report

Study: East; Area: Zone 5; Event: 9



## Flushing Field Report

Study: East; Area: Zone 5; Event: 9

Fire Hydrant	Notes	Pressure (psi) Static, Dynamic	Measured Flow (gpm)	Predicted Pressure (psi)	Predicted Flow (gpm)
3-0075				22.5	664

Valve	Operation	Notes	Flushing	Minimum	Recommended
V3-0195	Closed (prior) <input type="checkbox"/>		Time (min)	10.7	32.2
V3-0262	Closed (prior) <input type="checkbox"/>		Volume (gal)	7,118.9	21,356.8
V3-0199	Closed (prior) <input type="checkbox"/>		Start Time _____		
V3-0201	Closed (prior) <input type="checkbox"/>		End Time _____		
V3-0151	Closed (prior) <input type="checkbox"/>		Operator _____		
V3-0358	Close <input type="checkbox"/>		Date _____		
V3-0180	Close <input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
	<input type="checkbox"/>				
<b>Pipe Run to be Cleaned</b>			<b>Water Quality</b>		
P-6554, P-3333, P-6679, P-6705, P-6777, P-6799, P-6054, P-6537, P-2190, P-6684,			Clear	<input type="checkbox"/>	<input type="checkbox"/>
P-6786			Colored	<input type="checkbox"/>	<input type="checkbox"/>
			Chlorine Residual		
			Turbidity		

Notes \_\_\_\_\_

## Flushing Field Report

Study: East; Area: Zone 5; Event: 9

### Final Actions

Valve	Operation	Notes
V3-0195	Reopen <input type="checkbox"/>	
V3-0262	Reopen <input type="checkbox"/>	
V3-0199	Reopen <input type="checkbox"/>	
V3-0201	Reopen <input type="checkbox"/>	
V3-0151	Reopen <input type="checkbox"/>	
V3-0358	Reopen <input type="checkbox"/>	
V3-0180	Reopen <input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	
	<input type="checkbox"/>	