

BACKUP MATERIAL

WP-032-16

<u>DATE</u>	<u>FROM</u>	<u>TO</u>	<u>SUBJECT</u>
4/1/16	FL/PBC HD	USD	Warning Letter

FL/PBC HD-Florida Department of Health PBC

Mission:

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



Rick Scott
Governor

Celeste Philip, MD, MPH
Interim State Surgeon General

Vision: To be the Healthiest State in the Nation

April 1, 2016

Certified Mail #7014 3490 0001 3689 4841
Return Receipt Requested

Louis Aurigemma, Executive Director
City of Riviera Beach Utility District
600 W. Blue Heron Boulevard
Riviera Beach, FL 33404

RECEIVED

APR 08 2016

City of Riviera Beach
UTILITY DISTRICT

Re: Warning Letter WP-032-16
Riviera Beach Utility District
PWS #4501229
Palm Beach County

Dear Mr. Aurigemma:

The Florida Department of Health Palm Beach County (Department) conducted a review of the Pre-Compliance Reports on March 6 and 8, 2016 which resulted in possible violations of Chapters 62-550 and 62-555, *Florida Administrative Code, (F.A.C.)* and 40 CFR Subpart I.

During the review the Department noted the following possible violations:

- Rule 62-555.350(c), F.A.C.-The system failed to maintain the minimum combined chlorine residual of 0.6 mg/L within the distribution system during the February 2016 compliance period at the following locations:

February 27, 2016 (Distribution Repeat)

4860 Caribbean Boulevard, 0.5mg/L	4846 Caribbean Boulevard, 0.2mg/L
4884 Caribbean Boulevard, 0.4mg/L	5766 Parke Avenue, 0.2mg/L
5788 Parke Avenue, 0.2mg/L	5764 Parke Avenue, 0.3mg/L
5783 S. Bermuda Circle, 0.4mg/L	5793 S. Bermuda Circle, 0.2mg/L
5772 S. Bermuda Circle, 0.3mg/L	

February 28, 2016 (Distribution Repeat)

4860 Caribbean Boulevard, 0.4mg/L	4846 Caribbean Boulevard, 0.3mg/L
4884 Caribbean Boulevard, 0.3mg/L	5766 Parke Avenue, 0.3mg/L
5788 Parke Avenue, 0.4mg/L	5764 Parke Avenue, 0.2mg/L
5783 S. Bermuda Circle, 0.3mg/L	5793 S. Bermuda Circle, 0.3mg/L
5772 S. Bermuda Circle, 0.4mg/L	

APR 08 2016

City of Riviera Beach Utility District
 Warning Letter WP-032-16
 Page 2 of 3

City of Riviera Beach
 UTILITY DISTRICT

- Rule 62-550.310(5)(a)2., F.A.C.- The system exceeded the maximum contaminant level (MCL) (5% of samples) for total coliform within the distribution system during the following compliance period: February 2016-^{39%}~~53%~~ of the distribution samples were TC+.

February 17, 2016 (Routine Compliance)

5010 N. Ocean Drive, TC+

27/70

February 25, 2016 (Distribution Routine)

1057 W. 6th Street, TC+

1901 Avenue S, TC+

1301 Grandview Place, TC+

4860 Caribbean Boulevard, TC+

5783 S. Bermuda Circle, TC+

1160 W. 10th Street, TC+

1229 W. 25th Street, TC+

1501 Avenue U, TC+

5766 Parke Avenue, TC+

February 26, 2016 (Distribution Repeat)

4846, 4860 and 4872 Caribbean Boulevard, TC+

5766 and 5764 Parke Avenue, TC+

5772, 5783 and 5793 S. Bermuda Circle, TC+

February 27, 2016 (Distribution Repeat)

4860, 4846 and 4884 Caribbean Boulevard, TC+

5766, 5778 and 5764 Parke Avenue, TC+

5783, 5793 and 5772 S. Bermuda Circle, TC+

- 40 CFR Subpart I, 141.402(a)(2)-The system failed to submit triggered samples from each well in which a total coliform positive sample was collected during the February 2016 compliance period.

Violations of Florida Statutes or administrative rules may result in liability for damages and restoration, and the judicial imposition of civil penalties, pursuant to sections 403.121(4)(a), (5), (6) and (8) and 120.57(4), Florida Statutes.

Please contact Pamela Lape at (561)-837-5947, within 15 days of receipt of this Warning Letter to arrange a meeting to discuss this matter. The Department is interested in receiving any facts you may have that will assist in determining whether any violations have occurred. You may bring anyone with you to the meeting that you feel could help resolve this matter.

RECEIVED

APR 08 2016

City of Riviera Beach Utility District
Warning Letter WP-032-16
Page 3 of 3

City of Riviera Beach
UTILITY DISTRICT

Please be advised that this Warning Letter is part of an agency investigation, preliminary to agency action in accordance with section 120.57(5), Florida Statutes. We look forward to your cooperation in completing the investigation and resolving this matter.

For the Division Director,



Darrel J. Graziani, P.E., R.S.
Environmental Administrator, Water Programs
Division of Environmental Public Health
Florida Department of Health Palm Beach County

DG/pl

cc: FDEP SW District Office: Michele Owens via email-Michele.Owens@dep.state.fl.us
FDOHPBC File: WP-032-16